

**ONTARIO BUILDING CODE SUPPLEMENTARY STANDARD SB-10  
PROJECT INFORMATION**

Project:	Location:
Building Permit Application No.:	Date:

Architectural Designer Information*	Mechanical Designer Information*	Electrical Designer Information*
_____	_____	_____
Name	Name	Name
_____	_____	_____
Address	Address	Address
_____	_____	_____
City Province	City Province	City Province
_____	_____	_____
Signature Date(YY/MM/DD)	Signature Date(YY/MM/DD)	Signature Date(YY/MM/DD)

\*IF MORE DESIGNERS ARE INVOLVED, PROVIDE ADDITIONAL COPIES OF THIS FORM.

THIS CHECKLIST IS A CONVENIENCE DOCUMENT ONLY AND IS BASED ON THE ENERGY EFFICIENCY REQUIREMENTS DESCRIBED IN THE ONTARIO BUILDING CODE SUPPLEMENTARY STANDARD SB-10 DIVISION 3. THIS CHECKLIST IS NOT A SUBSTITUTE FOR COMPLYING WITH THE REQUIREMENTS OF THE ONTARIO BUILDING CODE. WHILE CARE HAS BEEN TAKEN TO ENSURE ACCURACY OF THIS CHECKLIST, DESIGNERS AND BUILDING OFFICIALS MUST REFER TO THE ACTUAL WORDING AND REQUIREMENTS OF THE ONTARIO BUILDING CODE (O.REG. 350/06 AND AMENDMENTS UP TO AMENDING O.REG. 315/12).

THIS CHECKLIST IS MADE AVAILABLE FOR CODE USERS BY THE MINISTRY OF MUNICIPAL AFFAIRS AND HOUSING. USERS SHOULD ALWAYS CONSULT WITH THE AUTHORITY HAVING JURISDICTION, IF THE CHECKLIST IS GOING TO BE SUBMITTED TO THAT AUTHORITY. THE MINISTRY OF MUNICIPAL AFFAIRS AND HOUSING DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR OVERSIGHTS RESULTING FROM THE INFORMATION CONTAINED HEREIN.

PLEASE FILL IN THE ACTUAL VALUES INSTALLED AND CHECK BOXES AS THEY APPLY.

**OBC SB-10 COMPLIANCE SUMMARY**

**Energy Efficiency Design:**

There are three energy compliance options to meet the requirements of OBC SB-10 Division 3. Please select the compliance option selected for this project. The energy efficiency of all buildings must be designed to:

Compliance Path		Forms to Complete
(A) Achieve the energy efficiency levels attained by conforming to the ASHRAE 90.1-2013, "Energy Standard for Buildings Except Low-Rise Residential Buildings" and Chapter 2 of SB-10 (Division 3). <b><i>This compliance path includes both prescriptive and performance path options. Please proceed to Form A.</i></b>	<input type="checkbox"/> YES	FORM A
(B) Achieve the energy efficiency levels attained by conforming to the National Energy Code of Canada for Buildings 2015 and Chapter 3 of SB-10 (Division 3). <b><i>This compliance path includes both prescriptive and performance path options. Please proceed to Form B.</i></b>	<input type="checkbox"/> YES	NECB
(C) Section 7 "Energy Efficiency" of 2014 ANSI/ASHRAE/USGBC/IES 189.1, excluding Sections 7.2.b, 7.4.7.3, 7.4.8 and 7.5 as described in SB-10 (Division 3).	<input type="checkbox"/> YES	FORM C

**OBC SB-10 AND ASHRAE 189.1 - 2014 – COMPLIANCE SUMMARY****Form C**

Project:	Location of Project:
Building Permit Application No.:	Climate Zone:

**ASHRAE 90.1 – 2013 COMPLIANCE AS MODIFIED BY ASHRAE 189.1-2014**

*The building design complies with the mandatory provisions of the following sections:*

ASHRAE 90.1-2013 Standard Section	Compliance Column	Form
5.4 BUILDING ENVELOPE AS MODIFIED BY SECTION 7.3 OF ASHRAE 189.1-2014	<input type="checkbox"/> YES	FORM C-5.4
5.5 BUILDING ENVELOPE Prescriptive Requirements Building Envelope Trade-Off	<input type="checkbox"/> YES	FORM C-5.5 or FORM C-5.6
6.4 HEATING, VENTILATING AND AIR CONDITIONING AS MODIFIED BY SECTION 7.3 OF ASHRAE 189.1-2014	<input type="checkbox"/> YES	FORM C-6.4
7.4 SERVICE WATER HEATING SYSTEMS AND EQUIPMENT AS MODIFIED BY SECTION 7.3 OF ASHRAE 189.1-2014	<input type="checkbox"/> YES	FORM C-7.4
8.4 POWER AS MODIFIED BY SECTION 7.3 OF ASHRAE 189.1-2014	<input type="checkbox"/> YES	FORM C-8.4
9.4 LIGHTING AS MODIFIED BY SECTION 7.3 OF ASHRAE 189.1-2014	<input type="checkbox"/> YES <input type="checkbox"/> YES	FORM C-9.4 FORM C-9.5
10.4 OTHER EQUIPMENT AS MODIFIED BY SECTION 7.3 OF ASHRAE 189.1-2014	<input type="checkbox"/> YES	FORM C-10.4
ASHRAE 189.1 SECTION 7 REQUIREMENTS	<input type="checkbox"/> YES	FORM 189.1

*Note that the performance option under Section 7.2.b of ASHRAE 189.1-2014 may not be used, as indicated in SB-10 2017 Division 3, Chapter 1, 1.1.2.1.(1).(c). If a performance option is desired, then the applicant should instead use one of the performance compliance options available under either the ASHRAE 90.1-2013 or NECB 2015 standards per SB-10 2017 Division 3, or 13% better than SB-10 2017 Division 2 per Part 12, 12.2.1.2.(2).(a).*

**ASHRAE 90.1-2013– MANDATORY PROVISIONS** **Form C-5.4**

<b>SECTION 5.4 MANDATORY PROVISIONS</b>	
Building insulation has been designed to comply with section 5.4.1 of ASHRAE 90.1-	<input type="checkbox"/> YES
Building fenestration and doors have been designed to comply with section 5.4.2 of ASHRAE 90.1-2013., as modified by Section 7.4.2.3 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES
Building air leakage has been designed to comply with section 5.4.3 of ASHRAE 90.1-2013 as modified by Section 7.3.1.1 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES

**ASHRAE 90.1-2013 & SB-10 – SECTION 5.5 – PRESCRIPTIVE ENVELOPE OPTION** **Form C-5.5-1**

<b>Section 5.5 Overall Building Design Requirements</b>	
<i>The building design must comply with the following general requirements. If any of these requirements are not met, the prescriptive path cannot be pursued. Consider the building envelope trade-off compliance as per Section 7.4.2.7 of ASHRAE 189.1-2014</i>	
Gross Wall Area: _____ m <sup>2</sup> Vertical Fenestration Area: _____ m <sup>2</sup> Vertical fenestration area is less than 40% of the gross wall area as per Section 5.5.4.2.1 of ASHRAE 90.1-2014, as modified by Section 7.4.2.4 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES
Gross Roof Area: _____ m <sup>2</sup> Skylight Area: _____ m <sup>2</sup> Total skylight area does not exceed 3% of the gross roof area	<input type="checkbox"/> YES
Where the main entrance is located on the south orientation and the south-oriented wall area is larger than west-oriented wall area, and where the south-oriented wall area is larger than east-oriented wall area, per ASHRAE 90.1-2013 5.5.4.5, either: (a) total east and west vertical fenestration areas are each less than 25% of total vertical fenestration area for the whole building, or (b) east and west area-weighted SHGC is less than area-weighted SHGC for total fenestration Expanded upon by Section 7.4.2.8 of ASHRAE 189.1-2014. See Form 189.2-C.	<input type="checkbox"/> YES <input type="checkbox"/> N/A  <input type="checkbox"/> YES <input type="checkbox"/> N/A
Exception (from ASHRAE 90.1-2013 Section 5.5.4.5): _____	
For Climate Zone 5, minimum skylight fenestration area conforms to the requirements of ASHRAE 90.1-2013 5.5.4.2.3.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
Identify ASHRAE 90.1-2013 Table used for maximum U-Factors or minimum RSI-Values, as modified by Section 7.4.2.1 of ASHREA 189.1-2014 : _____	

**Complete the table on Form C-5.5-2 to show compliance for all envelope components. Attach as many copies of this form as required to ensure that all envelope components are represented.**

*For all opaque surfaces, compliance must be demonstrated by meeting either:*

1. *The minimum R-values of insulation added in framing cavities and continuous insulation as specified in Tables 5.5-5 to 5.5-7 as modified by Section 7.4.2 of ASHRAE 189.1-2014.*
2. *The maximum U-factor, C-factor, or F-factor for the entire assembly as specified in Tables 5.5-5 to 5.5-7 as modified by Section 7.4.2 of ASHRAE 189.1-2014. U-factor is to be determined from tables in Appendix A of ASHRAE 90.1-2013 or through calculation methods described in ASHRAE 90.1-2013 Appendix Section A9 and modified by Section 7.4.2 of ASHRAE 189.1-2014.*

*For all fenestration products, compliance with U-factors, SHGC and VT must be determined for the overall fenestration product.*

1. *Fenestration shall have a U-factor and SHGC not greater than those specified in Tables 5.5-5 to 5.5-7 as modified by section 7.4.2.1 and 7.4.2.6 of ASHRAE 189.1-2014.*
2. *Where automatic daylighting controls are required in accordance with Section 9.4.1.1(e) or (f), fenestration shall have a ratio of VT divided by SHGC not less than that specified in Tables 5.5-5 through 5.5-7 for the appropriate fenestration area.*
3. *U-factor to be determined through CSA or NFRC rating or by using ASHRAE 90.1-2013 Appendix A default values.*

Please complete the following table to include information on all walls, roofs, doors, and floors used in the design.

<b>OPAQUE BUILDING ENVELOPE COMPONENTS</b>					
Opaque Element - Description <sup>(1)</sup>	Space Conditioning Category <sup>(2)</sup>	Class of Construction <sup>(3)</sup>	Criteria Max. U-Value <sup>(4)</sup> or Min RSI	Design U-Value <sup>(4)</sup> or RSI	Area Weighted Avg. Used <sup>(5)?</sup>
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH				<input type="checkbox"/> Y <input type="checkbox"/> N

Please complete the following table to include information on all fenestration products used in the design.

<b>FENESTRATION ENVELOPE COMPONENTS</b>									
Fenestration - Description <sup>(1)</sup>	Space Conditioning Category <sup>(2)</sup>	Class of Construction <sup>(3)</sup>	U-Value <sup>(4)</sup>		SHGC <sup>(6)</sup>		VT/SHGC		Area Weighted Average Used <sup>(5)?</sup>
			Crit.	Des.	Crit.	Des.	Crit.	Des.	
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N
	<input type="checkbox"/> NR <input type="checkbox"/> R <input type="checkbox"/> SH								<input type="checkbox"/> Y <input type="checkbox"/> N

- (1) Indicate if Element is a Wall, Roof, Floor, Door, Window or Skylight and a Tag or Description (eg Wall – W1).
- (2) Select from Non-residential (NR), Residential (R), or Semiheated (SH).
- (3) Select from the subclasses of roofs, walls, floors, doors and fenestration provided in Tables 5.5-5 to 5.5-7 (eg. Steel Framed for walls), as modified by Sections 7.4.2.1 and 7.4.2.2 of ASHREA 189.1-2014. Note that curtain wall systems are considered a steel framed wall.
- (4) F-Factors can be used for floors and C-Factors for below Grade Walls as applicable.
- (5) Elements of the same type, space category, and class of construction can be averaged using area weighting to show compliance only if U-Values are used.
- (6) Design SHGC may be higher than the criteria if one of the exceptions from ASHRAE 90.1-2013 5.5.4.4.1 or 5.5.4.4.2 is applicable as modified by 7.4.2.6 of ASHRAE 189.1-2014. Please use the space below to identify the fenestration elements (if any) which an exception for SHGC is being claimed.
- (7) Design VT/SHGC ratio may be lower than the criteria if one of the exceptions from ASHRAE 90.1-2013 5.5.4.6 is applicable. Please use the space below to identify the fenestration elements (if any) which an exception for VT/SHGC is being claimed.

<b>SHGC and VT/SHGC EXCEPTIONS</b>	
Fenestration Element	SHGC or VT/SHGC exception from ASHRAE 90.1-2013 5.5.4.4.1, 5.5.4.4.2, or 5.5.4.6

**Note that this option may only be pursued using the procedure described in ASHRAE 90.1-2013 Section 5.6 as modified by the requirements of Section 7.4.2.7 and 7.4.2.1 of ASHRAE 189.1-2014.**

Calculated EPF for proposed building\*: \_\_\_\_\_

Calculated EPF for budget building\*: \_\_\_\_\_

Envelope performance factor (EPF) for proposed building is less than or equal to the envelope performance factor of the budget building.	<input type="checkbox"/> YES
All components of the building envelope shown on architectural drawings or installed in existing buildings have been separately described and modeled in the proposed building design, with exception for envelope assemblies that cover less than 5% of the total area of its corresponding assembly type, and whose area can be included with another similar assembly (based on thermal properties and orientation) as noted in Section 5.6.1.1.	<input type="checkbox"/> YES
A software program* incorporating the requirements of ASHRAE 90.1-2013 as modified by SB-10 has been used to calculate the EPF. A report from this software is attached.  Name of software: _____	<input type="checkbox"/> YES

*\*Note that the EPF must be calculated by a simulation program which includes the requirements of ASHRAE 90.1-2013.*

SECTION 6 HVAC – 6.4 MANDATORY PROVISIONS & 6.5 PRESCRIPTIVE REQUIREMENTS		Form C-6.4
Reference		Standard Compliance
<b>Mandatory Provisions</b>		
6.4.1	Equipment shown in 6.8.1-1 through 6.8.1-13 meets the minimum performance as modified by Section 7.4.3.1 in ASHRAE 189.1-2014 at the specified rating conditions in accordance with the test procedures in the tables.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
	Permission: : If the building design complies with the prescriptive requirements of ASHRAE 189.1-2014 Standard Renewables Approach as per Section 7.4.1.1.1, then the building design equipment is to comply with Section 6.4.1 of ASHRAE 90.1-2013 requirements. Section 7.4.3.1 of ASHRAE 189.1-2014 can be disregarded.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
6.4.2.1	Load calculations for heating and cooling systems are done as per ASHRAE Standard 183-2007 for selection of all equipment and systems.	<input type="checkbox"/> YES <input type="checkbox"/> NO
6.4.2.2	Pressure drop through each device and pipe segment in the critical circuit at design conditions has been calculated in accordance with generally accepted engineering standards and handbooks.	<input type="checkbox"/> YES <input type="checkbox"/> NO
6.4.3	Mandatory controls requirements are met by all the equipment in the building as outlined in Section 6.4.3, as modified by Section 7.4.3.2 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> NO
6.4.4.1	Ductwork, piping, and equipment insulation meets the requirements of Section 6.4.4.1, as modified by Section 7.4.3.8 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> NO
6.4.4.2	Construction documents specify sealing and pressure testing of ductworks and plenums as per Section 6.4.4.2.	<input type="checkbox"/> YES <input type="checkbox"/> NO
6.4.5	Site-assembled or site-constructed walk-in coolers and freezers shall conform to the requirements of Section 6.4.5.	<input type="checkbox"/> YES <input type="checkbox"/> NO
6.4.6	All refrigerated display cases shall conform to the requirements of Section 6.4.6., including Section 6.4.1.1 and Tables 6.8.1-1 through 6.8.1-13 as modified by Section 7.4.3.1 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
	Permission: : If the building design complies with the prescriptive requirements of ASHRAE 189.1-2014 Standard Renewables Approach as per Section 7.4.1.1.1, then the building design equipment is to comply with Section 6.4.6 of ASHRAE 90.1-2013 requirements. Section 7.4.3.1 of ASHRAE 189.1-2014 can be disregarded.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
<b>Prescriptive Requirements</b>		
6.5.1	Each cooling system that has a fan employs either airside or waterside economizer unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.1.1	Airside economizers are capable of modulating outdoor air dampers to provide up to 100% design airflow for cooling and the system provides relief capacity for such airflow.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.1.2.1	Waterside economizers are capable of cooling supply air up to 100% of the expected system cooling load at the conditions listed under Section 6.5.1.2.1, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.1.2.2	Waterside economizer systems with pressure drop greater than 45kPa are isolated from main cooling loop to reduce pumping input in the normal cooling mode.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.1.3	Economizer systems incorporate integrated economizer controls per ASHRAE 90.1-2013 6.5.1.3	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.1.4	Economizer operation does not increase the building heating energy use during normal operation, except as allowed under ASHRAE 90.1-2013 6.5.1.4	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.1.5	Systems with hydronic cooling and humidification systems designed to maintain inside humidity at a dew-point temperature greater than 2°C use a water economizer if required by ASHRAE 90.1-2013 6.5.1.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.2	Simultaneous heating and cooling is limited with compliant zone, hydronic system, dehumidification, and humidification controls as per Section 6.5.2, as modified by 7.4.3.4 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.3	Cooling system fan controls comply with the requirements of 6.5.3.2 and 6.5.3.3.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.3.1	HVAC fan system power complies with Section 6.5.3.1 of ASHRAE 90.1-2013, as modified by Sections 7.5.3.5.1 and 7.5.3.5.2 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.4.1	Boiler systems with design input of ≥ 293 kW comply with the turndown ratio specified in Table 6.5.4.1.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.4.2	Pumping systems greater than 7.5 kW employ compliant variable flow controls, unless exempt	
6.5.4.3	Chilled water plants with more than one chiller and boiler plants with more than one boiler reduce loop water flow automatically whenever a chiller or boiler is shut down and isolated.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.4.4	Hydronic systems exceeding design capacity of 88 kW include controls to reset supply water temperature based on building loads or outdoor air temperature, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.4.5	Hydronic heat pumps and unitary air-conditioners include automatic water shutoff when the compressor is off (unless units are employing water economizer) and those having total pump system power greater than 3.7 kW have variable speed control.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
6.5.4.6	Chilled water and condenser water pipe is sized according to Table 6.5.4.6.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO

Note: Numbering is based on SI edition of ASHRAE 90.1-2013 and ASHRAE 189.1-2014

May, 2017

<b>6.5.5</b>	Open-circuit cooling towers have fans meeting the energy efficiency requirements of Section 6.5.5.3 and have flow turndown in compliance with 6.5.5.4.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.5.2</b>	All heat rejection equipment provide fan controls that comply with Section 6.5.5.2, with variable speed drives on fan motors $\geq 5.6$ kW.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.6.1</b>	Exhaust air energy recovery is provided for fan systems meeting the conditions listed on Table 6.5.6.1. Energy recovery bypass is available to permit air economizer operation as per Section 6.5.1.1., as modified by Section 7.4.3.6 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.6.2</b>	Condenser heat recovery system for heating or preheating hot water is provided, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.7.1</b>	Kitchen exhaust systems are designed as per Section 6.5.7.1, as modified by Section 7.4.3.7 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.7.1.5</b>	Specifications call for performance testing of kitchen exhaust systems.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.7.2</b>	Laboratory fume hoods with a total exhaust system flow $> 2,360$ L/S comply with the variable air volume control requirements of 6.5.7.2.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.8.1</b>	Heating of unenclosed spaces is done by radiant heating, except loading docks with air curtains.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.9</b>	Cooling equipment with hot-gas bypass controls is designed with multiple steps of unloading or continuous capacity modulation, with capacity limits as indicated in Table 6.5.9 for VAV systems. Constant volume units do not have hot gas bypass.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.10</b>	All conditioned spaces with a door to the exterior have door switches interlocked with heating and cooling controls per Section 6.5.10, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>6.5.11</b>	Refrigeration systems that are comprised of refrigerated display cases, walk-in coolers, or walk-in freezers connected to remote compressors, remote condensers, or remote condensing units meet the requirements of Sections 6.5.11.1 through 6.5.11.2.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO

SECTION 7 SERVICE WATER HEATING – 7.4 MANDATORY PROVISIONS AND 7.5 PRESCRIPTIVE REQUIREMENTS		
Reference	Item	Standard Compliance
7.4.1	Load calculations for heating and cooling systems are done in accordance with manufacturer's published sizing guidelines or generally accepted engineering standards and handbooks for selection of all equipment and systems.	<input type="checkbox"/> YES <input type="checkbox"/> NO
7.4.2	Equipment used solely for heating potable water, pool heaters, and hot water storage tanks meets or exceeds the efficiency requirements and testing criteria of Table 7.8, as modified by Section 7.4.4.1 of ASHRAE 189.1-2014, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	Permission: : If the building design complies with the prescriptive requirements of ASHRAE 189.1-2014 Standard Renewables Approach as per Section 7.4.1.1.1, then the building design equipment is to comply with Section 7.4.2 of ASHRAE 90.1-2013 requirements. Section 7.4.3.1 of ASHRAE 189.1-2014 can be disregarded.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	List exemption:	
7.4.3	The following service hot water piping is insulated to levels shown in Table 6.8.3-1: <ul style="list-style-type: none"> <li>a. Recirculating system piping, including piping of a circulating tank type water heater.</li> <li>b. The first 2.4m of outlet piping for a constant temperature non-recirculating storage system.</li> <li>c. Inlet pipe between storage tank and heat trap in a non-recirculating storage system.</li> <li>d. Pipes that are externally heated (e.g. heat tracing).</li> </ul>	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.4.1	All water-heating systems have temperature controls that are adjustable down to 49°C or lower. <ul style="list-style-type: none"> <li>• Exception: Equipment that must be protected from corrosion, as per manufacturer's installation instructions.</li> </ul>	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.4.2	Systems designed with pipe heating systems such as heat trace have temperature or time controls to disable during extended periods without hot water demand.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.4.3	Public lavatories have outlet temperature controls that limit the discharge temperature to 43°C.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.4.4	Tanks with remote heaters have circulation pump controls to limit operation of circulation pumps to a maximum of five minutes after the end of the heating cycle.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.5.1	Pool heaters have readily accessible ON/OFF switch without adjusting the thermostat setting. Gas-fired heaters do not have standing pilot lights.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.5.2	Per SB-10 7.4.5.2, heated exterior public pools and public spas shall be equipped with pool covers, unless over 60% of their energy for heating (computed over an annual operating season) is derived from site-recovered or site-solar energy.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.5.3	Pool heaters and circulation pumps have time switches, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.4.6	Heat traps are provided to all vertical risers serving storage water heaters and storage tanks.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>Prescriptive Requirement</b>		
7.5	Boiler systems that provide space heating as well as service water heating meet the conditions of Sections 7.5.1 and 7.5.2.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
7.5.3	Gas service hot-water systems with a total installed gas water-heating input capacity of 293 kW or greater, shall have a minimum input capacity-weighted average thermal efficiency of 90%, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO



## ASHRAE 90.1 & SB-10- SECTION 8,9 &10 POWER, LIGHTING AND OTHER EQUIPMENT

SECTION 8 POWER – MANDATORY PROVISIONS		Form C-8.4
Reference	Item	Standard Compliance
<b>8.4.1</b>	Feeder conductors and branch conductors are sized as per Section 8.4.1.	<input type="checkbox"/> YES <input type="checkbox"/> NO
<b>8.4.2</b>	At least 50% of all 125 volt 15- and 20-Ampere receptacles (installed in conference rooms, rooms used primarily for printing and/or copying functions, breakrooms, classrooms, and individual workstations), and at least 25% of branch circuit feeders (installed for modular furniture not shown on the construction documents), are provided with automatic receptacle controls that function on a) time-of-day schedule or b) occupant sensor or c) occupancy signal from another control or alarm system, with exceptions as listed, as modified by SB-10.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>8.4.3</b>	Unless exempted, measurement devices are shown in design documents to monitor the total electrical energy, as well as the electrical energy use separately for HVAC systems, interior lighting, exterior lighting, and receptacle circuits. For buildings with tenants, these systems are separately monitored for the total building and (excluding shared systems) for each individual tenant. Data recording and storage capabilities meet the requirements of 8.4.3.2.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>8.4.4</b>	Low Voltage Dry-Type Distribution Transformers meet nominal efficiencies shown in Table 8.1, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO

SECTION 9 LIGHTING– MANDATORY PROVISIONS CHECKLIST		Detailed Form C-9.4
Reference	Item	Standard Compliance
<b>9.4.1.1</b>	For each space in the building, all of the lighting control functions indicated in ASHRAE 90.1-2013 Table 9.6.1, for the appropriate space type in column A, have been implemented, as described by Section 9.4.1.1:	<input type="checkbox"/> YES <input type="checkbox"/> NO
	a. Local Control	
	b. Restricted to manual ON	
	c. Restricted to partial automatic ON	
	d. Bilevel lighting control	
	e. Automatic daylight responsive controls for sidelighting	
	f. Automatic daylight responsive controls for toplighting	
	g. Automatic partial OFF (full OFF complies)	
	h. Automatic full OFF	
<b>9.4.1.2</b>	Lighting for parking garages is controlled by automatic shutoff controls meeting the requirements outlined in Section 9.4.1.1i,	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	Lighting for parking garages is controlled by one or more devices that reduce lighting power of each luminaire by at least 30% when there is no activity within a zone for at most 30 minutes. Each lighting zone for this requirement cannot exceed 334 m <sup>2</sup> , except daylight transition zones and ramps without parking.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	Daylight transition zones in parking garages are controlled separately. These are automatically controlled to reduce by at least 50% from sunset to sunrise.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	Parking garage luminaires within 6m of perimeter walls that have a net opening-to-wall ratio of at least 40% automatically reduce power in response to daylight, except daylight transition zones and ramps without parking.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>9.4.1.3</b>	Additional control is provided to the special applications listed in Section 9.4.1.3	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>9.4.1.4</b>	Exterior lights are shut off by an automatic photosensor when available daylight is sufficient, unless exempt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	All building façade and landscape lighting is automatically shut off overnight as per 9.4.1.4, as modified by Sections 7.4.6.4 and 7.4.6.5 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> NO
	Exterior lighting not for façade or landscape, including for signage, is automatically controlled to reduce lighting power by at least 30% overnight or during inactive periods as per 9.4.1.4, as modified by Sections 7.4.6.4 and 7.4.6.5 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> NO
<b>9.4.2</b>	Exterior building lighting power complies with ASHRAE 90.1-2013 9.4.2 as modified by Section 7.4.6.1.2 of ASHARE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> NO
<b>9.4.3</b>	Third party functional testing of all lighting control devices and systems is specified in the construction documents.	<input type="checkbox"/> YES <input type="checkbox"/> NO

SECTION 9 LIGHTING – INSTALLED LIGHTING POWER COMPLIANCE		Form C-9.5
Reference		Standard Compliance
9.4.2	Exterior Lighting Zone _____ (Table 9.4.2-2) Modified by Section 7.4.6.1.2 of ASHRAE 189.1-2014.  <b>Total Installed Exterior Lighting Power _____ W ≤ value of exterior LPA _____ W *</b>  List any exemptions that apply:	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
<b>Prescriptive Requirements</b>		
9.5, 9.6	<b>9.5 INTERIOR LIGHTING POWER ALLOWANCE BY BUILDING TYPE</b>  Calculation of Interior Lighting Power Allowance (ILPA) by Building Type based on Table 9.5.1*, as modified by Section 7.4.6.1.1 of ASHRAE 189.1-2014. Building Type _____ Gross Lighted Area _____ m <sup>2</sup> Lighting Power Density _____ W/m <sup>2</sup>  <b>Total Installed Interior Lighting Power _____ W ≤ value of Interior LPA _____ W *</b>	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO
	<b>9.6 INTERIOR LIGHTING POWER ALLOWANCE BY SPACE FUNCTION</b>  Calculation of Interior Lighting Power Allowance (ILPA) for each space based on Table 9.6.1– *, as modified by Section 7.4.6.1.1 of ASHRAE 189.1-2014.  <b>Total Installed Interior Lighting Power _____ W ≤ value of Interior LPA _____ W *</b>  List any exemptions that apply:	<input type="checkbox"/> YES <input type="checkbox"/> N/A <input type="checkbox"/> NO

\* Calculation worksheets (FORM 9.5.2 and FORM 9.5.3) are available.

SECTION 10 OTHER EQUIPMENT - MANDATORY PROVISIONS		Form C-10.4
Reference	Item	Standard Compliance
10.4.1	Electric motors are in compliance with ASHRAE 90.1-2013 Tables 10.8-1, 10.8-2, 10.8-3 and 10.8-6, as applicable	<input type="checkbox"/> YES
10.4.2	Service water pressure booster pumps have pressure sensors to vary pump speed and/or start and stop pumps.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
	No devices are installed to reduce the pressure of all of the water supplied by any booster system or pump, except for safety devices.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
	Booster pumps shut off when there is no service water flow.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
10.4.3	All elevator cab lighting systems have efficacy of not less than 35 lumens per Watt.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
	Elevator cab ventilation fans for elevators without air conditioning consume less than 0.7 W-s/L at maximum speed.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
	Cab interior light and ventilation is de-energized when elevators are stopped and unoccupied with doors closed for over 15 minutes.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
10.4.4	Escalators and moving walks automatically slow to the minimum permitted speed in accordance with ASME A17.1/CSA B44 or applicable local code when not conveying passengers.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
10.4.5	The building is designed to facilitate future installation of means to measure and monitor energy use by each energy type described in Section 10.4.5.1, per SB-10 10.4.5.3.	<input type="checkbox"/> YES <input type="checkbox"/> N/A

**ASHRAE 90.1 & SB-10- SECTION 7 SERVICE WATER HEATING**

**Form 189.1**

ASHRAE 189.1-2014 - MANDATORY PROVISIONS		
Reference	Item	Standard Compliance
7.3.1	The building project is designed to comply with ASHRAE 90.1-2013 Section 5.4, 6.4, 7.4, 8.4, 9.4, and 10.4 as modified by Section 7 of ASHRAE 189.1-2014 as per Section 7.3.1 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES
7.3.2	Building project design complies with the on-site renewable energy system requirements of Section 7.3.2 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.3.3	The building project energy consumption management system complies with Section 7.3.3 of ASHRAE 189.1-2014	<input type="checkbox"/> YES

ASHRAE 189.1-2014 – PRESCRIPTIVE REQUIREMENTS		
Reference	Item	Standard Compliance
7.4.1	As per Section 7.4.1 of ASHRAE 189.1-2014, the building project design complies with all requirements of Section 7.4 of ASHRAE 189.1-2014. For all other criteria, the building project complies with ASHRAE 90.1-2013.	<input type="checkbox"/> YES
7.4.1.1	As per Section 7.4.1.1 the building project shall contain on-site renewable energy systems. Building project complies with either path: PATH 1 (Section 7.4.1.1.1) - Standard Renewables Approach: Baseline On-Site Renewable Energy Systems OR PATH 2 (Section 7.4.1.1.2) - Alternate Renewables Approach: Reduced On-Site Renewable Energy Systems and Higher-Efficiency Equipment	<input type="checkbox"/> PATH 1  <input type="checkbox"/> PATH 2
7.4.2.2	Single-rafter roof insulation complies with Section 7.4.2.2 of ASHRAE 189.1-2014	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.2.3	High-speed doors comply with Section 7.4.2.3 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.2.5	For climate zones 1 through 5, the building project complies with shading projection requirements of Section 7.4.2.5 of ASHRAE 189.1-2014. If applicable, list exceptions to 7.4.2.5:	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.2.8	The building project’s vertical fenestration orientation complies with Sections 7.4.2.8 List exceptions to 7.4.2.8:	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.3.9	Hotel/Motel guest rooms comply with Section 7.4.3.9 (including all subsections) of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.4.2	Pools heated to more than 32°C (90°F) will be insulated as per Section 7.4.4.2 of ASHRAE 189.1-2014 If applicable, list exceptions to 7.4.4.2:	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.5.1	Building project complies with automatic system requirements of Section 7.4.5.1 of ASHRAE 189.1-2014. If applicable, list exceptions to 7.4.5.1:	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.6.2	The building project’s occupancy sensor controls comply with Section 7.4.6.2 of ASHRAE 189.1-2014. If applicable, list exceptions to 7.4.6.2:	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.6.3	Automatic controls for Egress and Security lighting comply with Section 7.4.6.3 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.7.1	Path 2 Only: Alternate Renewables Approach Building project comply with applicable equipment efficiency requirements in Normative Appendix B. ENERGY STAR requirements can be disregarded for SB-10.	<input type="checkbox"/> YES <input type="checkbox"/> N/A
7.4.7.2	Supermarket building projects with floor area of 2,500 m <sup>2</sup> (25,000 ft <sup>2</sup> ) or greater shall comply with heat recovery requirements of Section 7.4.7.2 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES
7.4.7.4	All residential thermostats comply with section 7.4.7.5 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES
7.4.7.5	All refrigerated display cases comply with section 7.4.7.5 of ASHRAE 189.1-2014.	<input type="checkbox"/> YES