


ROMSPEN & RIC (MIDLAND LAND) INC.

WILSON AVENUE SUBDIVISION FUNCTIONAL SERVICING REPORT

AUGUST 04, 2022





WILSON AVENUE
SUBDIVISION
FUNCTIONAL SERVICING
REPORT

ROMSPEN
RIC (MIDLAND LAND) INC.

SERVICING REPORT
COPY

PROJECT NO.: 221-05962-00
CLIENT REF: N/A
DATE: AUGUST 04, 2022

WSP
201-1224 GARDINERS ROAD
KINGSTON, ON
CANADA K7P 0G2

T: +1 613 634-7373
F: +1 613 634-3523
WSP.COM

REVISION HISTORY

FIRST ISSUE

August 4, 2022		
Prepared by	Reviewed by	Approved By
Jared Delpellaro, B.A.Sc., C.Tech Dipl. Municipal Designer	Zhidong Pan, P.Eng., M.Eng. Senior Municipal Engineer	Steve Davidson, P.Eng., OLS (Ret.), MBA Manager, Municipal Engineering

SIGNATURES

PREPARED BY



Jared Delpellaro, B.A.Sc., C.Tech Dipl.
Municipal Engineer, Municipal Infrastructure

REVIEWED BY



Zhidong Pan, P.Eng., M.Eng
Senior Municipal Engineer, Municipal Infrastructure

REVIEWED BY



Steve Davidson, P. Eng. OLS (Ret.), MBA
Manager Municipal Engineering, Municipal Infrastructure



WSP Canada Inc. prepared this report solely for the use of the intended recipient, ROMSPEN and RIC (MIDLAND LAND) INC., in accordance with the professional services agreement. The intended recipient is solely responsible for the disclosure of any information contained in this report. The content and opinions contained in the present report are based on the observations and/or information available to WSP Canada Inc. at the time of preparation. If a third party makes use of, relies on, or makes decisions in accordance with this report, said third party is solely responsible for such use, reliance or decisions. WSP Canada Inc. does not accept responsibility for damages, if any, suffered by any third party as a result of decisions made or actions taken by said third party based on this report. This limitations statement is considered an integral part of this report.

The original of this digital file will be conserved by WSP Canada Inc. for a period of not less than 10 years. As the digital file transmitted to the intended recipient is no longer under the control of WSP Canada Inc. , its integrity cannot be assured. As such, WSP Canada Inc. does not guarantee any modifications made to this digital file subsequent to its transmission to the intended recipient.



TABLE OF CONTENTS

1	INTRODUCTION.....	1
2	OBJECTIVE	1
3	EXISTING CONDITIONS	1
3.1	OVERVIEW / EXISTING LAND USE.....	1
3.2	EXISTING ACCESS AND PARKING	2
3.3	EXISTING SANITARY AND WATER SERVICING	2
3.4	EXISTING TOPOGRAPHY & DRAINAGE	2
4	PROPOSED DEVELOPMENT	2
4.1	ADHERENCE TO ZONING AND RELATED REQUIREMENTS.....	2
4.2	ACCESS AND PARKING	2
4.3	SANITARY SERVICING	3
4.3.1	PROPOSED SYSTEM DESCRIPTION	3
4.3.2	DESIGN CRITERIA & calculated flows	3
4.3.3	PROPOSED SEWER SIZING	3
4.3.4	ADEQUACY OF MUNICIPAL INFRASTRUCTURE	4
4.4	POTABLE WATER SUPPLY.....	4
4.4.1	PROPOSED SYSTEM DESCRIPTION	4
4.4.2	DESIGN CRITERIA & Calculated demands	4
4.4.3	FIRE FLOW DEMANDS	5
4.4.4	WATERMAIN MODELLING & RESULTS.....	5
4.4.5	SUMMARY	8
4.5	STORMWATER MANAGEMENT	9
5	APPROVAL AND PERMIT REQUIREMENTS	9
6	CONCLUSION	9



APPENDICES

- A** CIVIL DRAWINGS
- B** SANITARY SYSTEM CALCULATION
- C** WATER SYSTEM CALCULATIONS
- D** WATER MODELLING OUTPUTS & HYDRANT TESTING
- E** EMAIL CORRESPONDENCE

1 INTRODUCTION

WSP has been retained by Romspen and RIC (Midland Land) Inc. to complete a Site Servicing Report, Stormwater Management Report and the preliminary design for a draft subdivision plan located on Wilson Avenue in Belleville, Ontario. The following report provides discussion and details on the preliminary design for all servicing required for the draft subdivision plan.

2 OBJECTIVE

The objective of the site servicing report is to meet the requirements for the proposed modification of the site while adhering to municipal and provincial servicing guidelines.

3 EXISTING CONDITIONS

3.1 OVERVIEW / EXISTING LAND USE

The proposed subdivision is located in Belleville Ontario, south of Moira Street West, west of Sidney Street, north of Bridge Street West and east of Palmer Road. The existing site is currently zoned as Urban Holding and General Industrial, as per the City of Belleville’s zoning bylaw, and will therefore require a zoning bylaw amendment to facilitate the proposed residential development. The proposed subject site has an area of 7.78 ha and is currently vacant space with residential to the north, south and west and industrial to the east. The existing subject site area is shown below as outlined in Figure 3-1 below.




Figure 3-1: Existing Conditions Subject Site

3.2 EXISTING ACCESS AND PARKING

The existing site can be accessed via Wilson Avenue which ends at the easterly site limits.

3.3 EXISTING SANITARY AND WATER SERVICING

Currently within the limits of the subject site there is no sanitary or water servicing. East of the site, where the intended access point is on Wilson Avenue, there is one (1) existing 200 mm sanitary sewer and one (1) capped existing 150 mm watermain. West of the site, where the intended access point is on Palmer Road, there is one (1) existing 300 mm watermain. Southwest of the site on Sherwood Crescent (South leg), there is one (1) existing 200 mm sanitary sewer which runs southeast directly into the pumping station between Sherwood Crescent (south leg) and Benson Court.

3.4 EXISTING TOPOGRAPHY & DRAINAGE

The topographic survey (carried out on July 24th, 2014, by Watson Land Surveyors LTD.) shows the existing drainage with ground elevations ranging from 98.5 m to 111.2 m. The existing topography of the site shows that the majority of the site, approximately 6.62 ha, generally flows from north to south with some localized low and high points throughout the site. Approximately 1.17 ha of the north portion of the site drains to the northeast and northwest corners of the subject site.

4 PROPOSED DEVELOPMENT

The proposed development will include a total of 153 residential units consisting of 82 single detached units and 71 townhome units.

4.1 ADHERENCE TO ZONING AND RELATED REQUIREMENTS

The proposed development, based on the draft subdivision plan provided by the applicant, will require a zoning bylaw amendment to convert the subject site from vacant, derelict and underutilized historical industrial lands to residential uses. This will require the approval from The City of Belleville (The City).

4.2 ACCESS AND PARKING

The proposed access to the Wilson Avenue subdivision development will include the extension of Wilson Avenue to connect to Palmer Road to the west. This extension will provide access to the subdivision from the east and the west of the subject site. Additionally, there will be four (4) new local roads (Streets B, C, D & E) within the subject site to provide access to all residential lots. One (1) of the local roads, located on the north side of the proposed subdivision will end at the site limits with the opportunity to be extended and connected to Wilson Avenue during future development. Each home will include a driveway to allow for residential parking on each lot.

4.3 SANITARY SERVICING

4.3.1 PROPOSED SYSTEM DESCRIPTION

The subject site's sanitary system will connect to the municipal sanitary system on the east side of Sherwood Crescent (south leg) with a 200 mm diameter gravity sanitary service. All flow generated within the Wilson Avenue subdivision will flow to the southwest corner of the site via gravity sewers. The current downstream sanitary sewer is a 200 mm diameter gravity sewer on Sherwood Crescent (south leg) which runs south directly into the existing sanitary pumping station between Sherwood Crescent (south leg) and Benson Court.

4.3.2 DESIGN CRITERIA & CALCULATED FLOWS

Sanitary sewers and service laterals for the subject site were designed in accordance with the following publications:

- Design Guidelines for Sewage Works (2008) | Ministry of the Environment, Conservation, and Parks
- Site Plan Guidelines | City of Belleville
- Subdivision Development Guidelines & Technical Standards | City of Kingston

The City of Kingston Subdivision Development Guidelines & Technical Standards were used as design criteria for the Wilson Avenue servicing plan as the City of Kingston is the closest municipality with clearly defined design criteria that also meet the MECP guidelines.

The sanitary demand for the proposed Wilson Avenue Subdivision was determined by calculating the Average Daily Flow, Peak Flow and Peak Daily Flow. The highest demand calculated was the Peak Daily flow at 6.94 L/s which is further detailed in Appendix B and based on the inputs presented in Table 4-1.

Table 4-1: Sanitary System - Design Values

DESCRIPTION	VALUE USED	SOURCE
Population Per Unit	2.36 PPU	City of Kingston Population, Housing and Employment Growth Forecast, 2016 to 2046
Average Daily Flow / Capita	350 L/cap/day	City of Kingston Subdivision Development Guidelines & Technical Standards
Peaking Factor (Harmon)	4 (Max)	City of Kingston Subdivision Development Guidelines & Technical Standards
Total Extraneous Flow	0.28 L/s/ha	City of Kingston Subdivision Development Guidelines & Technical Standards

4.3.3 PROPOSED SEWER SIZING

The total sanitary flow for the site was calculated to be 6.94 L/s. Sanitary sewer diameters and slopes were selected such that the peak flows correspond to less than 80% of the pipe's conveyance capacity, as well as velocities within the permissible range of 0.6-3.0 m/s. Steps were used at sewer manholes to account for hydraulic losses incurred due to bends in accordance with the MECP Design Guidelines for Sewage Works.

Refer to Appendix B for detailed sanitary sewer sizing calculations.

4.3.4 ADEQUACY OF MUNICIPAL INFRASTRUCTURE

The sanitary system outlet for the development is an existing 200 mm diameter sewer running south to the existing lift station between Sherwood Crescent (south leg) and Benson Court. Prior to the development of the Wilson Avenue Subdivision a capacity review of the existing 200 mm sanitary sewer and the existing lift station should be completed. The capacity review will be required to verify if the additional sewage flow generated by the Wilson Avenue development can be accommodated through the existing infrastructure, including the existing 200 mm sanitary sewers, the existing lift station and forcemain system, or if upgrades will be required.

4.4 POTABLE WATER SUPPLY

4.4.1 PROPOSED SYSTEM DESCRIPTION

The subject site will be connected to the municipal water system on Palmer Road at the intersection of Bogart Crescent (north leg) and Palmer Road and on Wilson Avenue. The proposed 200 mm diameter service will connect to the existing 300 mm diameter municipal watermain on Palmer Road. Additionally, the proposed 200 mm diameter service will connect to the existing capped 150 mm diameter municipal watermain located within the Wilson Avenue right-of-way.

Refer to Appendix C for water service sizing calculations.

4.4.2 DESIGN CRITERIA & CALCULATED DEMANDS

Watermains and water services for the subject site were designed in accordance with the following publications:

- Design Guidelines for Drinking-Water Systems (2008) | Ministry of the Environment, Conservation, and Parks
- Site Plan Guidelines | City of Belleville
- Subdivision Development Guidelines & Technical Standards | City of Kingston
 - Water consumption rate – 350 L/c/d
 - Max day demand (MDD) factor – 2.75
 - Peak hour demand (PHD) factor – 4.25
 - Minimum system pressure under PHD – 280 kPa
 - Maximum system pressure - 700 kPa
 - Hazen – Williams Roughness C-Coefficient
 - C = 110 for 200 mm Watermain
 - C = 120 FOR 300 mm Watermain

Table 4-2: Calculated Domestic Water Demands.

	AVERAGE DAY DEMAND	MAXIMUM DAY DEMAND	PEAK HOUR DEMAND
Totals	1.46 L/s	4.02 L/s	6.22 L/s

4.4.3 FIRE FLOW DEMANDS

Required fire flow for the proposed development was determined in accordance with Fire Underwriters Survey – 2020 Water Supply for Public Fire protection (FUS). The fire flow for the proposed Wilson Avenue subdivision was determined based on the simple method for one and two family dwellings exceeding 450 sq.m., and row housing exposure distances.

Given the requirements for the proposed development, the resulting required fire flows were determined to be 4,000 L/min for a single family lot and 8,000 L/min for a row housing lot.

4.4.4 WATERMAIN MODELLING & RESULTS

In order to appropriately size the proposed watermain and private service lateral on the site a WaterGEMS (version 10.03.01.08) steady-state hydraulic model was constructed.

Within the model, two (2) options were simulated to verify the pressure within the system. Option 1 assumed that two connections to the existing water systems on Palmer Road and Wilson Avenue are relatively independent each other, so the proposed site would be serviced by two water resources. Option 2 assumed that water applied to the system via only the Palmer Road connection. A total of six (6) scenarios were simulated to confirm the adequacy of the proposed watermain design, three (3) scenarios were simulated for each of the two (2) options. All three (3) scenarios have corresponding requirements for residual pressures based on the demand scenario in the system which are dictated by the MECP Drinking Water Design Guidelines and City of Kingston Subdivision Development Guidelines & Technical Standards. Refer to Table 4-3 for a summary of model scenarios and associated pressure objectives.

Table 4-3: Watermain Pressure and Demand Objectives.

SCENARIOS	System Residual Pressure Thresholds
Average Daily Demand (ADD)	280 kPa – 700 kPa
Peak Hour Demand (PHD)	Min 280 kPa
Maximum Day Demand (MDD) + Fire Flow	Min 140 kPa

Boundary conditions, for water model purposes, were acquired through hydrant testing which was carried out by City of Belleville on June 10, 2022. Boundary conditions within the model were simulated using a pump component drawing water from a reservoir node, where pump curve definition was set based on flowed and static conditions. Refer to Table 4-4 and Table 4-5 for key results from the hydrant tested at 311 Palmer Road and the hydrant tested at 53 Wilson Avenue, respectively. Refer to Appendix D for hydrant test reporting.

Table 4-4: Hydrant Testing Results for 311 Palmer Road.

	Flow (L/s)	Pressure (kPa)
Static Condition	0	344.7
Flow Condition -1	66.3	303.4
Flow Condition - 2	116.3	289.6

Table 4-5: Hydrant Testing Results for 53 Wilson Avenue

	Flow (L/s)	Pressure (kPa)
Static Condition	0	330
Flow Condition - 1	30.0	289.6

The hydraulic analysis completed in WaterGEMS concluded the following results for both options under each demand scenario. Refer to Appendix D for model report outputs and associated map figures.

Given the design parameters, the proposed water distribution system can meet the required operating criteria, based on Option 1, pressure applied from both Palmer Road and Wilson Avenue. The modeling results for Option 1 are summarized in Table 4-6.

Table 4-6: Summary of Modeling System Pressures Option 1

Scenario	Flow (L/s)	Maximum Pressure (kPa)	Average Pressure (kPa)	Minimum Pressure (kPa)
Average Daily Demand (ADD)	1.46	363	344	324
Maximum Day Demand (MDD)	4.02	362	343	324
Peak Hour Demand (PHD)	6.22	361	342	323

Given the design parameters, the proposed water distribution system can meet the required operating criteria, based on Option 2, pressure applied from only Palmer Road. The modeling results for Option 2 are summarized in Table 4-7.

Table 4-7: Summary of Modeling System Pressures Option 2

Scenario	Flow (l/s)	Maximum Pressure (kPa)	Average Pressure (kPa)	Minimum Pressure (kPa)
Average Daily Demand (ADD)	1.46	343	324	304
Maximum Day Demand (MDD)	4.02	343	324	304
Peak Hour Demand (PHD)	6.22	342	323	304

The available fire flows at each modeled junction within the Wilson Avenue Subdivision for Option 1 are shown in Table 4-8.

Table 4-8: Summary of Modeled Available Fire Flows Option 1

Junction	Available Flow (l/s)
J-100	200.0
J-105	198.8
J-110	184.2
J-115	178.1
J-120	180.3
J-125	182.9
J-130	166.9
J-135	166.0
J-140	177.6
J-145	181.2
J-150	178.1
J-155	190.3
J-160	178.6
J-165	164.2
J-170	154.4
J-175	156.8
J-180	155.9
J-185	168.1
J-190	148.3
J-195	141.4
J-205	200.0
J-210	193.4

The available fire flows at each modeled junction within the Wilson Avenue Subdivision for Option 2 are shown in Table 4-9.

Table 4-9: Summary of Modeled Available Fire Flows Option 2

Junction	Available Flow (l/s)
J-100	200.0
J-105	176.5
J-110	167.2
J-115	162.7
J-120	164.9
J-125	167.3
J-130	153.5
J-135	152.9
J-140	164.0
J-145	166.0
J-150	163.6
J-155	172.5
J-160	163.5
J-165	149.2
J-170	140.6
J-175	143.0
J-180	141.9
J-185	153.2
J-190	163.8
J-195	129.3
J-205	200.0
J-210	172.2

4.4.5 SUMMARY

Due to discussion with City staff Option 1 was assumed to be the case as there is no direct connection between the watermain on Wilson Avenue and the watermain on Palmer Road, and water supplies from the two connections are independent. The correspondence between City staff is included in Appendix E. With no direct connection there will be no pressure drop in either the Wilson Avenue or Palmer Road watermain when drawing demand from the other watermain. Based on this assumption all junctions within the model report higher than the required fire flow throughout the site.

4.5 STORMWATER MANAGEMENT

The Stormwater Management plan for the proposed development will include an overall strategy for the entire Wilson Avenue Subdivision subject site. The plan will ensure that the post-development peak flow rate shall not exceed the pre-development conditions. To achieve this requirement on-site storm water storage is to be included. Additionally, quality control is necessary for the site's stormwater system meet the Quinte Conservation Authorities (QCA) guidelines and standards.

The Stormwater Management Report has been included in this package under separate cover and can be referenced for additional stormwater management details.

5 APPROVAL AND PERMIT REQUIREMENTS

The proposed subdivision development is subject to approval from the City of Belleville based on a zoning bylaw amendment and the subdivision application. In addition, the proposed sanitary sewers and stormwater works are assumed to be subject to MECP – Environmental Compliance Approval (ECA) based on the proposed land-use.

Based on coordination and review of QCA requirement WSP has completed a Stormwater Management report to support the zoning bylaw amendment and subdivision application. Refer to the Stormwater Management Report for further discussion and details related to ECA and QCA approvals.

6 CONCLUSION



- The proposed development will require connection to existing municipal roadways. An extension of Wilson Avenue to connect to Palmer Road to the west will be defined to accommodate access to and from the proposed subdivision. All asphalt cuts will be reinstated by City of Belleville standards complete with step connections.
- Municipal water and sanitary services will be used to service the proposed Wilson Avenue Subdivision. The new 200 mm diameter water service will connect to the existing municipal system on Palmer Road and on Wilson Avenue to create a looped network. The new 200 mm diameter sanitary service will connect to the existing municipal system southwest of the proposed development on Sherwood Crescent (south leg).
- For stormwater management please refer to the Stormwater Management Report provided with this package under separate cover. The Stormwater Management Report was intended to be read in conjunction with the Servicing Report.
- The Wilson Avenue Subdivision will require hydro, communications, gas and lighting to be designed in accordance with the applicable codes and standards to be designed by others.

APPENDIX

A

CIVIL DRAWINGS






EXISTING LEGEND:

- EDGE OF PAVEMENT
- CURB
- BOTTOM OF SLOPE
- TOP OF SLOPE
- WATERMAIN
- ST — STORM SEWER
- SA — SANITARY SEWER
- UG — UNDERGROUND UTILITY
- FENCE
- PROPERTY LINE
- SANITARY MANHOLE
- STORM MANHOLE
- ◇ CATCHBASIN
- ⊕ FIRE HYDRANT
- ⊖ WATERMAIN VALVE
- ⊕ TRANSFORMER
- UTILITY POLE
- ROAD SIGN
- CULVERT
- ASPHALT ROAD
- CONCRETE SIDEWALK
- EXISTING GRADE

PROPOSED LEGEND:


- ALIGNMENT
- EDGE OF PAVEMENT
- BARRIER CURB
- WATERMAIN
- ST — STORM SEWER
- SA — SANITARY SEWER
- SWALE
- INFILTRATION TRENCH
- SUB-CATCHMENT BOUNDARY
- PROPERTY LINE
- BOTTOM OF SLOPE
- TOP OF SLOPE
- STORM MANHOLE
- ◇ CATCHBASIN
- ⊖ SANITARY MANHOLE
- ⊕ FIRE HYDRANT
- ⊖ WATERMAIN VALVE
- CONCRETE SIDEWALK
- 100.00 LOT GRADE
- 100.00 ROAD GRADE
- ← FLOW ARROW



1 WILSON AVENUE - TYPICAL SECTION
SCALE: 1:100

PRELIMINARY
NOT FOR CONSTRUCTION

REV	DATE	DESCRIPTION	BY
2	2022-08-04	ISSUED AS DRAFT PLAN APPROVAL	SD
1	2022-07-25	ISSUED AS DRAFT FOR CLIENT REVIEW	SD



SEAL: _____

DISCLAIMER: THIS DRAWING AND DESIGN IS COPYRIGHT PROTECTED WHICH SHALL NOT BE USED, REPRODUCED OR REVISED WITHOUT WRITTEN PERMISSION BY WSP. THE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND UTILITY LOCATIONS AND REPORT ALL ERRORS AND OMISSIONS PRIOR TO COMMENCING WORK.

ORIGINAL SCALE: 1:750

DESIGNED BY: JD

DRAWN BY: JT

APPROVED BY: ZP

DATE: 2022-06-09

IF THIS BAR IS NOT 25mm LONG, ADJUST YOUR PLOTTING SCALE.

25mm

DISCIPLINE: CIVIL

wsp

WSP CANADA INC.
1224 GARDINERS ROAD, SUITE 201
KINGSTON, ONTARIO
CANADA K7P 0G2
PHONE: 613-634-7373
WWW.WSP.COM

CLIENT: ROMSPEN

CLIENT REF. #: -

TITLE: PRELIMINARY GRADING PLAN

PROJECT: WILSON AVENUE SUBDIVISION

DRAWING NUMBER: C1.1


REV: 2

C:\Users\jtd\OneDrive\Documents\2022\221-05962-00 - Wilson Avenue Subdivision\Drawings\01_Civil\01_production\221-05962-00_grading_plan_c1.1.dwg

APPENDIX

B

SANITARY SYSTEM CALCULATION

WSP Canada Inc. 1224 Gardiners Road, Suite 201 Kingston, ON, Canada K7P 0G2 T: 613-634-7373 www.wsp.com		Wilson Avenue Sanitary Flow Calculation								
Table B1: Theoretical Sewage Flows										
ID	Area (ha)	Single Detached	Townhomes	Population	Average Daily Flow (m ³ /day)	Harmon Peaking Factor	Peak Flow (L/s)	I/I	Peak Daily Flow (L/s)	
Wilson Avenue Subdivision	7.784	82	71	361	126.35	4	5.85	1.0897	6.94	
Residential Flow Generation (L/cap/day)		350	MECP Sewage Design Guide			Designed by:				
Assumed Population per Single Detached		2.36	City of Kingston Population Housig Employment Forecast			Jared Delpellaro, B.A.Sc, C.Tech. Dipl. Municipal Designer				
Assumed Population per Townhome		2.36	City of Kingston Population Housig Employment Forecast							
Inflow and Infiltration (L/s/ha)		0.14	Kingston Subdivision Guidelines			Reviewed by:				
Sewage Peak Flow Factor		3	MECP Sewage Design Guide			Zhidong Pan, P.Eng, Municipal Engineer				
Design Manning 'n' Value		0.013	MECP Sewage Design Guide							

Sanitary Sewer Calculation Sheet Wilson Avenue Subdivision



SITE INFORMATION				FLOW GENERATION								OUTLET PIPE DATA									
Street	FROM	TO	Contributing Area		Population			q (L/cap/d)	M	Peak Flow (L/s)	Peak Extraneous Flow (L/s)	Q (L/s)	SIZE (mm)	SLOPE (%)	CAPACITY (L/s)	Q/Qfull	VELOCITY (m/s)	LENGTH (m)	FALL (m)	OUTLET PIPE DATA	
			No.	Ha	Lots	P	IP(1000)													U/S	D/S
Wilson Ave Extension (Center of site)	SANMH208	SANMH209		0.428	5	12	0.012	350	4.00	0.19	0.06	0.25	200	1.25%	36.67	0.7%	1.17	70	0.874	99.274	98.400
	SANMH209	SANMH205		0.230	2	5	0.005	350	4.00	0.08	0.03	0.36	200	0.50%	23.19	1.6%	0.74	70	0.352	98.370	98.018
North Side of Street C	SANMH210	SANMH211		0.453	8	19	0.019	350	4.00	0.31	0.06	0.37	200	1.50%	40.17	0.9%	1.28	52	0.779	98.653	97.874
	SANMH211	SANMH212		0.563	10	24	0.024	350	4.00	0.38	0.08	0.83	200	0.50%	23.19	3.6%	0.74	69	0.346	97.874	97.529
North Side of Street E (Northeast Corner of the Site)	SANMH214	SANMH215		0.418	4	9	0.009	350	4.00	0.15	0.06	0.21	200	0.75%	28.40	0.7%	0.90	60	0.449	100.230	99.781
	SANMH215	SANMH216		0.606	21	50	0.050	350	4.00	0.80	0.08	1.10	200	1.25%	36.67	3.0%	1.17	84	1.056	99.781	98.725
	SANMH216	SANMH217		0.671	23	54	0.054	350	4.00	0.88	0.09	2.07	200	0.75%	28.40	7.3%	0.90	70	0.528	98.725	98.197
	SANMH217	SANMH218		0.221	5	12	0.012	350	4.00	0.19	0.03	2.30	200	0.75%	28.40	8.1%	0.90	14	0.107	98.167	98.060
	SANMH218	SANMH212		0.351	11	26	0.026	350	4.00	0.42	0.05	2.76	200	0.75%	28.40	9.7%	0.90	75	0.562	98.030	97.469
	SANMH212	SANMH213		0.368	11	26	0.026	350	4.00	0.42	0.05	4.07	200	0.50%	23.19	17.5%	0.74	71	0.357	97.469	97.111
	SANMH213	SANMH207		0.042	0	0	0.000	350	4.00	0.00	0.01	4.07	200	0.50%	23.19	17.6%	0.74	14	0.068	97.081	97.014
East Side of Street B (Northeast Capped Corner of the Site)	SANMH200	SANMH201		0.121	2	5	0.005	350	4.00	0.08	0.02	0.09	200	1.25%	36.67	0.3%	1.17	20	0.248	100.678	100.431
	SANMH201	SANMH202		0.410	7	17	0.017	350	4.00	0.27	0.06	0.42	200	0.50%	23.19	1.8%	0.74	68	0.339	100.431	100.092
	SANMH202	SANMH203		0.670	12	28	0.028	350	4.00	0.46	0.09	0.97	200	0.75%	28.40	3.4%	0.90	90	0.673	100.092	99.419
	SANMH203	SANMH204		0.316	3	7	0.007	350	4.00	0.11	0.04	1.13	200	1.50%	40.17	2.8%	1.28	14	0.209	99.389	99.180
	SANMH204	SANMH205		0.818	12	28	0.028	350	4.00	0.46	0.11	1.70	200	1.25%	36.67	4.6%	1.17	95	1.192	99.150	97.958
	SANMH205	SANMH206		0.486	8	19	0.019	350	4.00	0.31	0.07	2.44	200	0.50%	23.19	10.5%	0.74	65	0.327	97.958	97.632
	SANMH206	SANMH207		0.541	9	21	0.021	350	4.00	0.34	0.08	2.86	200	1.00%	32.80	8.7%	1.04	59	0.588	97.632	97.044
	SANMH207	SANMH219		0.000	0	0	0.000	350	4.00	0.00	0.00	6.93	200	1.00%	32.80	21.1%	1.04	54	0.535	96.984	96.449
SANMH219	SANMH220		0.000	0	0	0.000	350	4.00	0.00	0.00	6.93	200	1.25%	36.67	18.9%	1.17	116	1.451	96.389	94.937	
	SANMH220	EX. SANMH206		0.000	0	0	0.000	350	4.00	0.00	0.00	6.93	200	0.50%	23.19	29.9%	0.74	25	0.127	94.877	94.750


DESIGN PARAMETER			Designed By:		PROJECT:	
Manning's n =	0.013		Jared Depellaro, B.A.Sc., C.Tech Dipl.		Wilson Avenue Subdivision	
Residential Average Flow	350 L/cap/d	City of Kingston Technical Guidelines	Checked By:		LOCATION:	
Infiltration Rate (I) =	0.14 L/s/ha	City of Kingston Technical Guidelines				
Population Per Unit:	2.36	City of Kingston Population Housiq Employment Forecast	Zhidong Pan, P.Eng.		Wilson Avenue, Belleville, Ontario	
Min slope 1.0% (MH to MH)		City of Kingston Technical Guidelines			Project Number:	
Min cover for San main is 1.5m		City of Kingston Technical Guidelines			221-05962-00	
					25-Jul-22	

APPENDIX

C

WATER SYSTEM CALCULATIONS



WSP Canada Inc. 1224 Gardiners Road, Suite 201 Kingston, ON, Canada K7P 0G2 T: 613-634-7373 www.wsp.com				<h2 style="margin: 0;">Wilson Avenue Water Demand Calculation</h2>					
Table A1: Theoretical Water Demands									
ID	Land-Use	Demand (L/cap/day)	Population	Area (m ²)	Average Day Demand Required (L/s)	Maximum Day Demand Required (L/s)	Peak Hour Demand Required (L/s)	Maximum Day Demand + Fire Flow (L/S)	
Wilson Avenue Subdivision	Residential	350	361	77838.41	1.462	4.022	6.215	70.688	
Residential Flow Generation (L/cap/day)		350	MECP guide states 270-450		Designed by:				
Max Day Demand Multiplier		2.75	Kingston Subdivision Guidelines		Jared Delpellaro, B.A.Sc, C.Tech. Dipl. Municipal Designer				
Peak Hour Demand Multiplier		4.25	Kingston Subdivision Guidelines						
Fire Flow Demand (L/s)		66.67	FUS Table 7 & Table 8		Reviewed by:				
					Zhidong Pan, P.Eng, Municipal Engineer				

APPENDIX

D

WATER MODELLING
OUTPUTS & HYDRANT
TESTING

Fire Flow Calculator

1) Determine discharge (flow rate) from the flow hydrants.

$$Q = 29.83cd^2\sqrt{P} \quad [1]$$

where: Q = discharge, in GPM
 c = coefficient of discharge
 d = inside diameter of the outlet port, in in.
 P = pitot pressure, in psi

<p>Flow Hydrant # 1, Port # 1:</p> <p>input: hydrant # 53 Wilson Ave.</p> <p>c = 0.9</p> <p>d = 2.5 in</p> <p>P = 8 psi</p> <p>calculate: Q = 475 USGPM 395 IMPGPM 30 LPS</p>	<p>Flow Hydrant # 1, Port # 2:</p> <p>input: hydrant # 53 Wilson Ave.</p> <p>c = 0.9</p> <p>d = 2.5 in</p> <p>P = 1 psi</p> <p>calculate: Q = 168 USGPM 140 IMPGPM 11 LPS</p>	<p>Flow Hydrant # 2, Port # 1:</p> <p>input: hydrant # </p> <p>c = 0</p> <p>d = 0 in</p> <p>P = 0 psi</p> <p>calculate: Q = 0 USGPM 0 IMPGPM 0 LPS</p>	<p>Flow Hydrant # 2, Port # 2:</p> <p>input: hydrant # </p> <p>c = 0</p> <p>d = 0 in</p> <p>P = 0 psi</p> <p>calculate: Q = 0 USGPM 0 IMPGPM 0 LPS</p>
---	---	--	--

2) Determine available flow.


$$Q_r = Q_f \times \frac{(P_s - P_D)^{0.54}}{(P_s - P_R)^{0.54}} \quad [2]$$

where: Q_r = the flow available at the desirable residual pressure, in GPM
 Q_f = the sum of the flows from all hydrants from step 1, in GPM
 P_s = the measured static pressure at residual hydrant, in psi
 P_D = the desired residual pressure, in psi (normally 20 for fire flows)
 P_R = the measured residual pressure at residual hydrant, in psi

<p>input: residual hydrant # 34 Wilson Ave.</p> <p>Q_f = 336 USGPM</p> <p>P_s = 48 psi</p> <p>P_D = 20 psi</p> <p>P_R = 42 psi</p> <p>calculate: Q_r = 771 USGPM at 20 psi 642 IMPGPM 49 LPS</p>

[1] AWWA Manual M17, p. 44
 [2] AWWA Manual M17, p. 51

Available Flow



Fire Flow Calculator

1) Determine discharge (flow rate) from the flow hydrants.

$$Q = 29.83cd^2\sqrt{P} \quad [1]$$

where: Q = discharge, in GPM
 c = coefficient of discharge
 d = inside diameter of the outlet port, in in.
 P = pitot pressure, in psi

<p>Flow Hydrant # 1, Port # 1:</p> <p>input: hydrant # 311 Palmer Rd.</p> <p>c = 0.9</p> <p>d = 2.5 in</p> <p>P = 39 psi</p> <p>calculate: Q = 1048 USGPM 872 IMPGPM 66 LPS</p>	<p>Flow Hydrant # 1, Port # 2:</p> <p>input: hydrant # 311 Palmer Rd.</p> <p>c = 0.9</p> <p>d = 2.5 in</p> <p>P = 30 psi</p> <p>calculate: Q = 919 USGPM 765 IMPGPM 58 LPS</p>	<p>Flow Hydrant # 2, Port # 1:</p> <p>input: hydrant # </p> <p>c = 0</p> <p>d = 0 in</p> <p>P = 0 psi</p> <p>calculate: Q = 0 USGPM 0 IMPGPM 0 LPS</p>	<p>Flow Hydrant # 2, Port # 2:</p> <p>input: hydrant # </p> <p>c = 0</p> <p>d = 0 in</p> <p>P = 0 psi</p> <p>calculate: Q = 0 USGPM 0 IMPGPM 0 LPS</p>
---	--	--	--

2) Determine available flow.

$$Q_r = Q_f \times \frac{(P_s - P_D)^{0.54}}{(P_s - P_R)^{0.54}} \quad [2]$$

where: Q_r = the flow available at the desirable residual pressure, in GPM
 Q_f = the sum of the flows from all hydrants from step 1, in GPM
 P_s = the measured static pressure at residual hydrant, in psi
 P_D = the desired residual pressure, in psi (normally 20 for fire flows)
 P_R = the measured residual pressure at residual hydrant, in psi

input: residual hydrant # 300 Palmer Rd.

Q_f = 1838 USGPM

P_s = 50 psi


P_D = 20 psi

P_R = 42 psi


calculate: Q_r = 3753 USGPM at 20 psi 3124 IMPGPM 237 LPS

[1] AWWA Manual M17, p. 44
 [2] AWWA Manual M17, p. 51

Available Flow



Bentley WaterGEMS Water Distribution System Modeling Layout



(ONE PUMP MDD+FIRE)
FlexTable: Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Flow (Total Available) (L/s)
J-100	101.10	0.00	134.74	329	200.00
J-105	101.33	0.21	134.74	327	176.47
J-110	100.65	0.13	134.74	334	167.18
J-115	99.96	0.34	134.73	340	162.71
J-120	100.38	0.00	134.73	336	164.86
J-125	100.44	0.37	134.73	336	167.34
J-130	100.85	0.60	134.73	332	153.49
J-135	101.15	0.42	134.73	329	152.94
J-140	102.37	0.42	134.74	317	164.01
J-145	102.63	0.00	134.74	314	165.98
J-150	102.36	0.08	134.74	317	163.55
J-155	101.27	0.26	134.74	328	172.52
J-160	100.56	0.29	134.73	334	163.50
J-165	102.01	0.29	134.74	320	149.22
J-170	102.78	0.37	134.74	313	140.62
J-175	103.11	0.00	134.74	310	142.95
J-180	103.18	0.13	134.74	309	141.93
J-185	102.77	0.11	134.74	313	153.24
J-190	103.24	0.00	134.74	308	163.77
J-195	103.65	0.00	134.74	304	129.29
J-205	99.70	0.00	134.74	343	200.00
J-210	101.33	0.00	134.74	327	172.21

(ONE PUMP ADD)
FlexTable: Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Flow (Total Available) (L/s)
J-100	101.10	0.00	134.79	330	(N/A)
J-105	101.33	0.08	134.79	327	(N/A)
J-110	100.65	0.05	134.79	334	(N/A)
J-115	99.96	0.12	134.79	341	(N/A)
J-120	100.38	0.00	134.79	337	(N/A)
J-125	100.44	0.13	134.79	336	(N/A)
J-130	100.85	0.22	134.79	332	(N/A)
J-135	101.15	0.15	134.79	329	(N/A)
J-140	102.37	0.15	134.79	317	(N/A)
J-145	102.63	0.00	134.79	315	(N/A)
J-150	102.36	0.03	134.79	317	(N/A)
J-155	101.27	0.10	134.79	328	(N/A)
J-160	100.56	0.11	134.79	335	(N/A)
J-165	102.01	0.11	134.79	321	(N/A)
J-170	102.78	0.13	134.79	313	(N/A)
J-175	103.11	0.00	134.79	310	(N/A)
J-180	103.18	0.05	134.79	309	(N/A)
J-185	102.77	0.04	134.79	313	(N/A)
J-190	103.24	0.00	134.79	309	(N/A)
J-195	103.65	0.00	134.79	305	(N/A)
J-205	99.70	0.00	134.79	343	(N/A)
J-210	101.33	0.00	134.79	327	(N/A)

(ONE PUMP MDD)
FlexTable: Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Flow (Total Available) (L/s)
J-100	101.10	0.00	134.74	329	(N/A)
J-105	101.33	0.21	134.74	327	(N/A)
J-110	100.65	0.13	134.74	334	(N/A)
J-115	99.96	0.34	134.73	340	(N/A)
J-120	100.38	0.00	134.73	336	(N/A)
J-125	100.44	0.37	134.73	336	(N/A)
J-130	100.85	0.60	134.73	332	(N/A)
J-135	101.15	0.42	134.73	329	(N/A)
J-140	102.37	0.42	134.74	317	(N/A)
J-145	102.63	0.00	134.74	314	(N/A)
J-150	102.36	0.08	134.74	317	(N/A)
J-155	101.27	0.26	134.74	328	(N/A)
J-160	100.56	0.29	134.73	334	(N/A)
J-165	102.01	0.29	134.74	320	(N/A)
J-170	102.78	0.37	134.74	313	(N/A)
J-175	103.11	0.00	134.74	310	(N/A)
J-180	103.18	0.13	134.74	309	(N/A)
J-185	102.77	0.11	134.74	313	(N/A)
J-190	103.24	0.00	134.74	308	(N/A)
J-195	103.65	0.00	134.74	304	(N/A)
J-205	99.70	0.00	134.74	343	(N/A)
J-210	101.33	0.00	134.74	327	(N/A)

(ONE PUMP PHD)
FlexTable: Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Flow (Total Available) (L/s)
J-100	101.10	0.00	134.69	329	(N/A)
J-105	101.33	0.33	134.68	326	(N/A)
J-110	100.65	0.20	134.68	333	(N/A)
J-115	99.96	0.53	134.68	340	(N/A)
J-120	100.38	0.00	134.68	336	(N/A)
J-125	100.44	0.57	134.68	335	(N/A)
J-130	100.85	0.93	134.68	331	(N/A)
J-135	101.15	0.65	134.68	328	(N/A)
J-140	102.37	0.65	134.68	316	(N/A)
J-145	102.63	0.00	134.68	314	(N/A)
J-150	102.36	0.12	134.68	316	(N/A)
J-155	101.27	0.41	134.68	327	(N/A)
J-160	100.56	0.45	134.68	334	(N/A)
J-165	102.01	0.45	134.68	320	(N/A)
J-170	102.78	0.57	134.68	312	(N/A)
J-175	103.11	0.00	134.68	309	(N/A)
J-180	103.18	0.20	134.68	308	(N/A)
J-185	102.77	0.16	134.68	312	(N/A)
J-190	103.24	0.00	134.68	308	(N/A)
J-195	103.65	0.00	134.68	304	(N/A)
J-205	99.70	0.00	134.69	342	(N/A)
J-210	101.33	0.00	134.68	326	(N/A)

**(TWP PUMPS MDD+FIRE)
FlexTable: Junction Table**

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Fire Flow (Available) (L/s)
J-100	101.10	0.00	136.72	349	200.00
J-105	101.33	0.21	136.72	346	198.64
J-110	100.65	0.13	136.72	353	184.09
J-115	99.96	0.34	136.72	360	177.72
J-120	100.38	0.00	136.72	356	180.26
J-125	100.44	0.37	136.72	355	182.53
J-130	100.85	0.60	136.72	351	166.29
J-135	101.15	0.42	136.72	348	165.55
J-140	102.37	0.42	136.73	336	177.16
J-145	102.63	0.00	136.73	334	181.19
J-150	102.36	0.08	136.73	336	178.06
J-155	101.27	0.26	136.72	347	190.09
J-160	100.56	0.29	136.72	354	178.29
J-165	102.01	0.29	136.72	340	163.95
J-170	102.78	0.37	136.72	332	154.08
J-175	103.11	0.00	136.73	329	156.77
J-180	103.18	0.13	136.73	328	155.76
J-185	102.77	0.11	136.73	332	168.04
J-190	103.24	0.00	136.75	328	148.31
J-195	103.65	0.00	136.73	324	141.42
J-205	99.70	0.00	136.72	362	200.00
J-210	101.33	0.00	136.72	346	193.36

(TWO PUMPS ADD)
FlexTable: Junction Table

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Fire Flow (Available) (L/s)
J-100	101.10	0.00	136.62	348	(N/A)
J-105	101.33	0.33	136.62	345	(N/A)
J-110	100.65	0.20	136.62	352	(N/A)
J-115	99.96	0.53	136.62	359	(N/A)
J-120	100.38	0.00	136.62	355	(N/A)
J-125	100.44	0.57	136.62	354	(N/A)
J-130	100.85	0.93	136.62	350	(N/A)
J-135	101.15	0.65	136.62	347	(N/A)
J-140	102.37	0.65	136.63	335	(N/A)
J-145	102.63	0.00	136.63	333	(N/A)
J-150	102.36	0.12	136.63	335	(N/A)
J-155	101.27	0.41	136.62	346	(N/A)
J-160	100.56	0.45	136.62	353	(N/A)
J-165	102.01	0.45	136.62	339	(N/A)
J-170	102.78	0.57	136.62	331	(N/A)
J-175	103.11	0.00	136.63	328	(N/A)
J-180	103.18	0.20	136.63	327	(N/A)
J-185	102.77	0.16	136.63	331	(N/A)
J-190	103.24	0.00	136.68	327	(N/A)
J-195	103.65	0.00	136.63	323	(N/A)
J-205	99.70	0.00	136.62	361	(N/A)
J-210	101.33	0.00	136.62	345	(N/A)

**(TWO PUMPS MDD)
FlexTable: Junction Table**

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Fire Flow (Available) (L/s)
J-100	101.10	0.00	136.72	349	(N/A)
J-105	101.33	0.21	136.72	346	(N/A)
J-110	100.65	0.13	136.72	353	(N/A)
J-115	99.96	0.34	136.72	360	(N/A)
J-120	100.38	0.00	136.72	356	(N/A)
J-125	100.44	0.37	136.72	355	(N/A)
J-130	100.85	0.60	136.72	351	(N/A)
J-135	101.15	0.42	136.72	348	(N/A)
J-140	102.37	0.42	136.73	336	(N/A)
J-145	102.63	0.00	136.73	334	(N/A)
J-150	102.36	0.08	136.73	336	(N/A)
J-155	101.27	0.26	136.72	347	(N/A)
J-160	100.56	0.29	136.72	354	(N/A)
J-165	102.01	0.29	136.72	340	(N/A)
J-170	102.78	0.37	136.72	332	(N/A)
J-175	103.11	0.00	136.73	329	(N/A)
J-180	103.18	0.13	136.73	328	(N/A)
J-185	102.77	0.11	136.73	332	(N/A)
J-190	103.24	0.00	136.75	328	(N/A)
J-195	103.65	0.00	136.73	324	(N/A)
J-205	99.70	0.00	136.72	362	(N/A)
J-210	101.33	0.00	136.72	346	(N/A)

**(TWO PUMPS PHD)
FlexTable: Junction Table**

Label	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (kPa)	Fire Flow (Available) (L/s)
J-100	101.10	0.00	136.78	349	(N/A)
J-105	101.33	0.08	136.78	347	(N/A)
J-110	100.65	0.05	136.78	354	(N/A)
J-115	99.96	0.12	136.78	360	(N/A)
J-120	100.38	0.00	136.78	356	(N/A)
J-125	100.44	0.13	136.78	356	(N/A)
J-130	100.85	0.22	136.78	352	(N/A)
J-135	101.15	0.15	136.78	349	(N/A)
J-140	102.37	0.15	136.78	337	(N/A)
J-145	102.63	0.00	136.78	334	(N/A)
J-150	102.36	0.03	136.78	337	(N/A)
J-155	101.27	0.10	136.78	348	(N/A)
J-160	100.56	0.11	136.78	355	(N/A)
J-165	102.01	0.11	136.78	340	(N/A)
J-170	102.78	0.13	136.78	333	(N/A)
J-175	103.11	0.00	136.78	330	(N/A)
J-180	103.18	0.05	136.78	329	(N/A)
J-185	102.77	0.04	136.78	333	(N/A)
J-190	103.24	0.00	136.79	328	(N/A)
J-195	103.65	0.00	136.78	324	(N/A)
J-205	99.70	0.00	136.78	363	(N/A)
J-210	101.33	0.00	136.78	347	(N/A)

APPENDIX

E

EMAIL CORRESPONDENCE



Delpellaro, Jared

From: Lucciola, Darrin <dlucciola@belleville.ca>
Sent: June 8, 2022 2:15 PM
To: Davidson, Steve
Cc: Pan, Zhidong; Delpellaro, Jared; Hunter, Michael; Pinchin, Greg; Reinert, Richard
Subject: RE: Flow data

Hi Steve

We can certainly do this, but I can tell you right now for a fact that there will not be a pressure drop on Wilson Ave. when flowing Palmer Rd. There is absolutely no direct connection between these 2 mains. They are miles apart in terms of watermain connections.

Darrin

From: Davidson, Steve [mailto:Steve.P.Davidson@wsp.com]
Sent: June 8, 2022 2:01 PM
To: Lucciola, Darrin
Cc: Pan, Zhidong; Delpellaro, Jared; Hunter, Michael; Pinchin, Greg; Reinert, Richard
Subject: RE: Flow data

CAUTION: This email is **NOT** from the city of Belleville. Do **NOT** click links or open attachments unless you recognize the sender and know the content is safe!

Hi Darrin,

One additional thing I forgot to mention in my request, when we complete the hydrant testing along Palmer Road, can we have another pressure gauge on the fire hydrant at the west end of Wilson Avenue? The reason for the request is we want to determine the connectivity of the Palmer Road and Wilson Road mains, and find out if there is in fact a pressure drop when we flow the main on Palmer.

Thanks!
SD



Steve Davidson, P.Eng., OLS (Ret.), MBA
Manager, Municipal Engineering – Kingston & Cornwall

T+ 1 613-634-7373
T+ 1 613-856-0307 (Direct)



WSP Canada Inc.
1224 Gardiners Road, Suite 201
Kingston, ON
K7P 0G2 Canada

wsp.com